

## Site Lighting

### INTENT

To ensure that lighting contributes to the character of the site, provides pedestrian scale interest and security throughout the site and does not disturb adjacent developments and residences and the night sky.

### GUIDELINES

1. Lighting shall be provided throughout the site to provide a safe and comfortable atmosphere.
2. All lighting should be shielded from the sky and adjacent properties and structures, either through exterior shields or through optics within the fixture.
3. Accent lighting is encouraged but should be combined with functional lighting to highlight special focal points such as building/site entrances, public art and special landscape features.
4. Lighting should contribute to and integrate with the overall character of the site architecture or other site features.
5. Lighting in parking lots shall not exceed a maximum of 30 feet in height. Pedestrian scale lighting a maximum of 15 feet in height shall be provided throughout all Pedestrian Connections/Walkways.
6. Lighting design should comply with the Illuminating Engineering Society of North America's Recommended Practices and Design Guidelines, latest editions, for each applicable lighting type (i.e. Parking Lot, Walkways, etc.).

