

Lighting Retrofit Requirements

The following must be completed for projects which include retrofitting of luminaires:

REQUIREMENTS

- Electrical permits are required for retrofit of two or more luminaires.
- Request for inspection shall be made no later than 3 days after completion of the installation or 1 business day after any part of the installation has been energized.
- Electrical Contractor shall have electrician meet electrical inspector on site with ladder and open luminaries to allow inspection to be performed
- Electrical Contractor shall provide retrofit kit packaging at inspection showing listing label allowing use with the existing type luminaries
- Electrical Contractor shall ensure all of the following:
 1. Luminaries are properly supported as required by NEC 410.30 & NEC 410.36;
 2. Luminaries are properly grounded as required by NEC 410.42 through NEC 410.46;
 3. Conductors shall be properly installed as required by NEC 410.48 through NEC 410.68;
and
 4. Disconnecting means shall be provided as required by NEC 410.130 (G).