



SIDE VIEW

NOTES:

1. SWING CHECK VALVE TO BE LOCATED
2. INSTALLATION OF GUARD POSTS AS REQUIRED BY FIRE DEPARTMENT.
3. AT BALL DRIP VALVE-INSTALL 1/2 C.Y. 3/4" WASHED ROCK WRAPPED IN FILTER FABRIC.

DRAWING NUMBER	STD5-20
SCALE	NONE
REVISION DATE	4/16
DEPARTMENT	PW