



NOTES

1. LIMITS OF TRENCH
 W = MAXIMUM WIDTH OF TRENCH
 FOR PIPES 15" OR LESS IN DIAMETER
 W= 40" MINIMUM
 FOR PIPES 18" OR GREATER IN DIAMETER
 $W = 1 \frac{1}{2} \times \text{I.D.} + 18"$
2. GRAVEL BACKFILL FOR PIPE ZONE BEDDING SHALL CONSIST OF CRUSHED, PROCESSED, OR NATURALLY OCCURRING GRANULAR MATERIAL. IT SHALL BE ESSENTIALLY FREE FROM VARIOUS TYPES OF WOOD WASTE OR OTHER EXTRANEEOUS OR OBJECTIONABLE MATERIALS. IT SHALL HAVE SUCH CHARACTERISTICS OF SIZE AND SHAPE THAT IT WILL COMPACT READILY PER WSDOT 9-03.12 (3).
3. PEA GRAVEL, SAND, $\frac{5}{8}$ " CHIPS, CDF AND $\frac{5}{8}$ " CSTC MAY BE REQUIRED AT THE DISCRETION OF THE PUBLIC WORKS INSPECTOR.
4. ALL FOUNDATION MATERIAL, IF REQUIRED, SHALL BE FOUNDATION MATERIAL CLASS "A" PER WSDOT SPEC 9-03.17
 REQUIRED COMPACTION PROCEDURES SHALL COMPLY WITH WSDOT SPEC 2-06. SEE LYNNWOOD STD. 6-17 FOR ADDITIONAL INFORMATION.