



NOTE:

- (A) ROMAC AND MUELLER DOUBLE STRAP SERVICE SADDLES WITH C.C. THREAD OR I.P. THREAD TO BE USED ON ALL MAINS.
 - (B) CORPORATION STOPS: 1 1/2" & 2" - FORD BALLCORP CORPORATION STOP #FB400 OR #FB500 (EQUAL MUELLER OR A.Y. MCDONALD BRASS MAY BE SUBSTITUTED).
 - (C) PACK JOINT AND APPROPRIATE STAINLESS STEEL STIFFENER OR COMPRESSION FITTING WITH 1/8 OR 1/4 BEND AS REQUIRED.
 - (D) COPPER TYPE K
 - (E) METER SETTERS: 1 1/2" - FORD #VBH86-12B-11-66
2" - FORD #VBH87-12B-11-77
VERTICAL IN - VERTICAL OUT WITH BYPASS.
 - (F) METERS SHALL BE INSTALLED BY THE CITY WATER DIVISION AT OWNERS EXPENSE.
 - (G) METER BOXES SHALL BE: CARSON SERIES 1730,(PLASTIC) OR FOGTITE B10 #2 (CONCRETE). SET BELOW BYPASS, WITH TOUCH READ ADAPTER.
 - (H) COPPER TYPE K OR POLYETHYLENE LINE; A # 10 COPPER TRACE WIRE IS REQUIRED FOR POLYETHYLENE PIPE.
- PRIVATE LINE INSTALLATION SHALL COMPLY WITH 7-15.3 OF THE 1998 STANDARD SPECIFICATIONS FOR ROAD, BRIDGE AND MUNICIPAL CONSTRUCTION.