



NOTES:

1. IF USED ON DESIGN DRAWINGS, ENGINEER TO PROVIDE DIMENSIONS.
2. THE RISER ROOM SHALL CONTAIN ALL SPRINKLER CONTROL VALVES, BACKFLOW ASSEMBLY (UNLESS PROHIBITED BY THE WATER PURVEYOR), FIRE PUMP, IF PROVIDED, AND THE FIRE ALARM CONTROL PANEL(S). NO OTHER USES OR UTILITIES INCLUDING STORAGE SHALL BE ALLOWED IN THE RISER ROOM.
3. RISER ROOMS SHALL BE OF A SIZE THAT WILL ALLOW A MINIMUM OF 36" CLEARANCE ALONG THE FRONT OF ALL RISER(S) AND EQUIPMENT AND A MINIMUM OF AT LEAST 18" ON THE THREE REMAINING SIDES OF ALL SPRINKLER RISERS, PUMPS AND APPURTENANCES
4. DIAMETER 2" LARGER THAN THE PIPE FOR PIPE 1 TO 3-1/2" AND 4" LARGER FOR PIPE 4" AND LARGER (NFPA 13 18.4.2).
5. MINIMUM 36" CLEARANCE ALONG THE FRONT OF ALL RISERS AND EQUIPMENT AND A MINIMUM OF AT LEAST 18" ON THE THREE REMAINING SIDES OF ALL SPRINKLER RISERS, PUMPS AND APPURTENANCES.

DRAWING NUMBER	F-5
SCALE	NONE
REVISION DATE	11/20
DEPARTMENT	PW