


PLAN



SECTION

NOTES:

- ① QUARRY SPALLS 4" - 8"
- ② SEE FIGURE 4.2 IN THE CURRENT ADOPTED STORMWATER MANAGEMENT MANUAL FOR WESTERN WASHINGT DETAILS. NOTE: THE MINIMUM 100LF OF ENTRANCE SHALL BE REDUCED TO THE MAXIMUM PRACTICABLE SIZE WHEN THEN SIZE OR CONFIGURATION OF THE SITE DOES NOT ALLOW THE FULL LENGTH (100LF).
- ③ EXISTING DRIVEWAY RAMP, OR SITE ACCESS ROAD 20' WIDE MIN. MATERIAL MUST BE EQUAL TO OR BETTER THAN SPECIFIED IN NOTE 1.
- ④ A SEPARATION GEOTEXTILE SHALL BE PLACED UNDER THE SPALLS TO PREVENT FINE SEDIMENT FROM PUMPING UP INTO THE ROCK PAD. THE GEOTEXTILE SHALL MEET THE FOLLOWING STANDARDS:
 GRAB TENSILE STRENGTH (ASTM D4751) 200 PSI MIN.
 GRAB TENSILE ELONGATION (ASTM D4632) 30% MAX.
 MULLEN BURST STRENGTH (ASTM D3786-80A) 400 PSI MIN.
 AOS (ASTM D4751) 20-45 (U.S. STANDARD SIEVE SIZE)



TEMPORARY CONSTRUCTION
ENTRANCE

I:\Standard_Plans

DRAWING NUMBER	STD2-9
SCALE	NONE
REVISION DATE	03/17
DEPARTMENT	PW