



NOTES:

1. GUARD POSTS SHALL BE 6' LONG MIN., 6" DIA, CONCRETE FILLED STEEL PIPE. PAINTED WITH TWO COATS OF "RUST-O-LEUM" NO. 2766, HI GLOSS YELLOW PAINT OR CATERPILLAR YELLOW.
2. TOP OF GUARD POST SHALL BE LEVEL WITH THE TOP OF HYDRANT OR 36" WHICHEVER IS GREATER. GUARD POST SHALL BE NO CLOSER THAN 36" TO THE HYDRANT PROTRUSIONS.
3. VALVE MARKER POST SHALL BE 42" PORTABLE TRAFFIC DELINEATOR POST W/TWO REFLECTOR STRIPS. THEY SHALL BE FURNISHED NEW AND UNUSED AND BURIED 24" DEEP, TO LEAVE 18" EXPOSED AS A MARKER POST THE LETTER "V" AND THE DISTANCE TO THE VALVE SHALL BE STENCILED ON THE POST WITH 2" HIGH NUMERALS, WITH BLACK ENAMEL PAINT.
4. VALVE MARKER POSTS SHALL BE INSTALLED FOR ALL VALVES LOCATED IN UNIMPROVED OR UNPAVED AREAS. VALVE MARKER POSTS SHALL BE SET AS DIRECTED BY THE PUBLIC WORKS INSPECTOR IN A SAFE AND REASONABLY CONSPICUOUS LOCATION.
5. VALVE MARKER POSTS ARE NOT REQUIRED FOR AUXILIARY HYDRANT VALVES.
6. A 3-FOOT (914 MM) CLEAR SPACE SHALL BE MAINTAINED AROUND THE CIRCUMFERENCE OF FIRE HYDRANTS, EXCEPT AS OTHERWISE REQUIRED OR APPROVED. (IFC 507.5.5)
7. INSTALL A 3' X 3' X 4" ALL-WEATHER PAD APPROVED BY THE FIRE MARSHAL'S OFFICE CENTERED ON THE HYDRANT.

DRAWING NUMBER	STD5-8
SCALE	NONE
REVISION DATE	12/16
DEPARTMENT	PW