



**NOTES:**

1. MATERIAL FOR PEDESTRIAN BARRIER SHALL BE ALUMINUM (ASTM B-429) OR GALVANIZED STEEL (ASTM 120) AS APPROVED BY THE CITY ENGINEER.
2. SEE STANDARD DRAWING No. 3-27 FOR ADDITIONAL FABRICATION AND SPECIFICATION REQUIREMENTS.
3. PROVIDE SLIP JOINTS AT STAIRWAY EXPANSION JOINTS AND AT EVERY 24 FEET ON CENTER MAXIMUM.
4. ADDITIONAL INTERNATIONAL BUILDING CODE REQUIREMENTS MAY APPLY.



**PEDESTRIAN BARRIER**

DRAWING NUMBER	STD3-26
SCALE	NONE
REVISION DATE	2/2013
DEPARTMENT	PW