



NOTES:

1. MATERIAL FOR PEDESTRIAN BARRIER SHALL BE ALUMINUM (ASTM B-429) OR GALVANIZED STEEL (ASTM 120) AS APPROVED BY THE CITY ENGINEER.
2. SEE STANDARD DRAWING No. 3-27 FOR ADDITIONAL FABRICATION AND SPECIFICATION REQUIREMENTS.
3. PROVIDE SLIP JOINTS AT STAIRWAY EXPANSION JOINTS AND AT EVERY 24 FEET ON CENTER MAXIMUM.
4. ADDITIONAL INTERNATIONAL BUILDING CODE REQUIREMENTS MAY APPLY.



PEDESTRIAN BARRIER

I:\Standard_Plans

DRAWING NUMBER	STD3-26A
SCALE	NONE
REVISION DATE	2/2013
DEPARTMENT	PW