

# RESIDENTIAL ROOFTOP SOLAR SYSTEM ACCELERATED SELF CERTIFICATION CHECKLIST FORM

Contractor can apply for an accelerated permit where the PV system meets the requirements listed in this checklist. All project site plan, plans, one-line diagram and supporting documentation must be provided on site for the inspector prior to requesting inspection. Building and electrical permits are required for the installation or replacement of solar/photovoltaic (PV) systems, including rooftop arrays and PV water heaters.

## PROJECT INFORMATION:

Project Applicant Name/Company \_\_\_\_\_

Site Owner Name \_\_\_\_\_

Site Address or Parcel Number \_\_\_\_\_

PV System Description (include manufacturer and model number of major equipment) \_\_\_\_\_

## RESIDENTIAL BUILDING/FIRE QUALIFICATIONS:

	Yes	No
1. Photovoltaic (PV) system is designed and proposed for a detached one- or two- family dwelling or townhouse not more than three stories above grade or detached accessory structure.	<input type="checkbox"/>	<input type="checkbox"/>
2. PV system is being installed by a licensed contractor.	<input type="checkbox"/>	<input type="checkbox"/>
3. PV system is designed for rooftop of a house in general compliance with applicable codes.	<input type="checkbox"/>	<input type="checkbox"/>
4. Mounting system is engineered and designed for PV.	<input type="checkbox"/>	<input type="checkbox"/>
5. Rooftop is made from lightweight material such as a single layer of composition shingles, metal roofing, or cedar shingles.	<input type="checkbox"/>	<input type="checkbox"/>
6. To address uplift, panels are mounted no higher than 18" above the surface of the roofing to which they are affixed. Except for flat roofs, no portion of the system may exceed the highest point of the roof (or ridge).	<input type="checkbox"/>	<input type="checkbox"/>
7. Total dead load of panels, supports, mountings, raceways, and all other appurtenances weigh no more than three and one-half (3.5) pounds per square foot.	<input type="checkbox"/>	<input type="checkbox"/>
8. Supports for solar panels are installed to spread the dead load across as many roof-framing members as needed to ensure that at no point loads in excess of fifty (50) pounds are created.	<input type="checkbox"/>	<input type="checkbox"/>
9. The installation will comply with the manufacturer's instructions.	<input type="checkbox"/>	<input type="checkbox"/>
10. Per IRC M2301.2.9, roof and wall penetrations will be flashed and sealed in accordance with IRC Ch. 9 to prevent entry of water, rodents, and insects.	<input type="checkbox"/>	<input type="checkbox"/>
11. Home is code compliant to setbacks and height, or code allows expansion of nonconformity for solar panels.	<input type="checkbox"/>	<input type="checkbox"/>
12. System complies with International Residential Code Ch. 23 for solar thermal energy systems.	<input type="checkbox"/>	<input type="checkbox"/>
13. Roof-mounted collectors and supporting structure are constructed of noncombustible materials or fire-retardant-treated wood equivalent to that required for the roof construction per IRC M2301.2.2.1.	<input type="checkbox"/>	<input type="checkbox"/>
14. Roof-mounted collectors and supporting structure are constructed of noncombustible materials or fire-retardant-treated wood equivalent to that required for the roof construction per IRC M2301.2.2.1.	<input type="checkbox"/>	<input type="checkbox"/>

15. I have prepared the roof plan with Roof access points and pathways for firefighters will be provided per IFC 1205.2.1.1 <ul style="list-style-type: none"> <li>At least two 36-inch-wide pathways are provided on separate roof planes, from lowest roof edge to ridge and</li> <li>Not fewer than one pathway shall be provided on the street or driveway side of the roof</li> <li>For each roof plane with a photovoltaic array, not fewer than one 36-inch-wide pathway from lowest roof edge to ridge shall be provided on the same roof plane as the photovoltaic array, on an adjacent roof plane or straddling the same and adjacent roof planes.</li> </ul>	<input type="checkbox"/>	<input type="checkbox"/>
16. An electrical solar permit will be pulled.	<input type="checkbox"/>	<input type="checkbox"/>

**ELECTRICAL QUALIFICATIONS:**

	Yes	No
17. PV modules, inverters, and combiner boxes are identified for use in PV systems.	<input type="checkbox"/>	<input type="checkbox"/>
18. The inverters are listed and labeled in accordance with UL 1741 and are listed for utility interaction. [IRC M2302.4]	<input type="checkbox"/>	<input type="checkbox"/>
19. The AC interconnection point is on the load side of service disconnect. [NEC 690.64(B)]	<input type="checkbox"/>	<input type="checkbox"/>
20. The system meets all current NEC, City and Washington Cities Electrical Code requirements.	<input type="checkbox"/>	<input type="checkbox"/>
21. For Split-Buss modules the AC interconnection must be one of the six service disconnects. <input type="checkbox"/> If not applicable, check here	<input type="checkbox"/>	<input type="checkbox"/>
22. Maximum load added to the panelboard is based on the rating of the panelboards bus/main OCPD combination in accordance with NEC 705.12(D)(2)(3)(b), and is limited to (check combination that applies): <ul style="list-style-type: none"> <li><input type="checkbox"/> 225 amp bus/200 amp main OCPD - 13,440 AC watts, maximum 70 amp inverter OCPD.</li> <li><input type="checkbox"/> 225 amp bus/225 amp main OCPD - 8,640 AC watts, maximum 45 amp inverter OCPD.</li> <li><input type="checkbox"/> 200 amp bus/200 amp main OCPD - 7,860 AC watts, maximum 40 amp inverter OCPD.</li> <li><input type="checkbox"/> 150 amp bus/150 amp main OCPD - 5,760 AC watts, maximum 30 amp inverter OCPD.</li> <li><input type="checkbox"/> 125 amp bus/125 amp main OCPD - 4,800 AC watts, maximum 25 amp inverter OCPD.</li> <li><input type="checkbox"/> 125 amp bus/100 amp main OCPD - 9,600 AC watts, maximum 50 amp inverter OCPD.</li> <li><input type="checkbox"/> 100 amp bus/100 amp main OCPD - 3,840 AC watts, maximum 20 amp inverter OCPD.</li> <li><input type="checkbox"/> <b>Other- Electrical Permit with Plan Review Required</b></li> </ul> <p><b>Note 1:</b> Listed un-altered factory main/bus combination. Alteration of the panelboard main OCPD will require plan review.</p> <p><b>Note 2:</b> The circuit conductors and overcurrent devices shall be sized to carry not less than 125 percent of the maximum currents as calculated in 690.8(A). The rating or setting of overcurrent devices shall be permitted in accordance with 240.4(B) and (C). NEC 690.8(B)(1)</p> <p><b>Note 3:</b> If a panelboard employs a snap switch rated 30 amperes or less in any branch circuit, it cannot be rated more than 200 amperes unless there is a supply side overcurrent protection at 200 amperes or less within the panelboard. This requirement does not apply to panelboards equipped with circuit breakers. Section 408.36(A) of the NEC.</p>	<input type="checkbox"/>	<input type="checkbox"/>
23. I have prepared the following Electrical One-Line Diagram to submit with my permit application: <ul style="list-style-type: none"> <li><input type="checkbox"/> Standard Electrical Diagram- 6 Strings or Less</li> <li><input type="checkbox"/> Standard Electrical Diagram- 4 Strings or Less</li> <li><input type="checkbox"/> Standard Electrical Diagram- Micro Inverter</li> <li><input type="checkbox"/> <b>None of the above- Electrical Permit with Plan Review Required</b></li> </ul>	<input type="checkbox"/>	<input type="checkbox"/>
24. I agree to schedule an on-the-ground pre-check inspection of all materials being used, such as, PV panels, micro inverters, mounting components, and PV panel configurations prior to roof mounting.	<input type="checkbox"/>	<input type="checkbox"/>

If you answered yes to all of the above questions, the project qualifies for the expedited permitting process.