



NOTES:

1. HYDRANTS AND ALL MATERIALS TO BE APWA OR AWWA APPROVED (HYDRANTS SHALL BE MUELLER CENTURION A-423 OR AMERICAN DARLING B62B).
2. 5-1/4" MAIN VALVE SEAT.
3. 1-1/4" OPERATING NUT AND CAP NUT FOR 2-1/2" PORTS - CHAINS REMOVED.
4. NATIONAL STANDARD THREAD ON THE 2-1/2" PORT.
5. NATIONAL STANDARD THREAD W/4" NON LOCKING STORZ ADAPTER AND CAP ON 4 1/2" PORT.
6. IF HYDRANT RISES THROUGH CONCRETE, USE 1/2X4" EXPANSION STRIP AROUND HYDRANT BARREL. IN ADDITION, INSTALLATION OF THE HYDRANT ON PRIVATE PROPERTY SHALL EQUAL OR EXCEED THE STANDARDS FOR INSTALLATION OF PUBLIC FIRE HYDRANTS IN THE CITY OF LYNNWOOD.
7. PROVIDE BOLLARDS FOR VEHICULAR TRAFFIC PROTECTION WHEN NECESSARY PER STD. PLAN F-2.
8. 4 1/2" PORT TO BE FACING STREET OR ROADWAY FOR FIRE ENGINE ACCESS.
9. BREAK-OFF FLANGE TO BE 2" ABOVE GROUND LEVEL.
10. INSTALL A 3' X 3' X 4" ALL-WEATHER PAD APPROVED BY THE FIRE MARSHAL'S OFFICE CENTERED ON THE HYDRANT. PROVIDE MIN. 4" CSBC BASE.
11. HYDRANT CONNECTION PIPE TO BE 6" DUCTILE IRON CLASS 52, ANY INTERMEDIATE JOINTS TO BE MJ WITH RETAINER GLANDS (MEGA LUG® OR EQUIVALENT) OR FIELD LOK® GASKET.
12. FIRE HYDRANTS SHALL BE PAINTED WITH TWO COATS OF HIGH GLOSS SAFETY YELLOW "RUST-OLEUM" TYPE PAINT.
13. INSTALL RAYOLITE MODEL 44 BLUE REFLECTOR OR APPROVED EQUAL. OFFSET AT CENTERLINE OF ROAD ON SIDE WITH HYDRANT