



NOTES:

1. GUARD POSTS SHALL BE 6' LONG MIN., 6" DIA, CONCRETE FILLED SCHEDULE 40 STEEL PIPE. PAINT WITH TWO COATS OF "RUST-O-LEUM" NO. 2766, HI GLOSS YELLOW PAINT.
2. TOP OF GUARD POST SHALL BE LEVEL WITH THE TOP OF HYDRANT, FDC, OR 36" WHICHEVER IS GREATER. GUARD POST SHALL BE NO CLOSER THAN 36" TO THE HYDRANT PROTRUSIONS.
3. A 3-FOOT (914 MM) CLEAR SPACE SHALL BE MAINTAINED AROUND THE CIRCUMFERENCE OF FIRE HYDRANTS, EXCEPT AS OTHERWISE REQUIRED OR APPROVED. (IFC 507.5.5)