



NOTES:

1. PROVIDE BOLLARDS FOR VEHICULAR TRAFFIC PROTECTION WHEN NECESSARY. BOLLARDS AND POSITION TO BE IDENTICAL TO HYDRANT SHOWN PER STD. F-2.
2. MINIMUM 4" PIPE (NFPA 13 16.12.4).
3. EACH FIRE DEPARTMENT CONNECTION TO SPRINKLER SYSTEMS SHALL BE DESIGNATED BY A SIGN HAVING RAISED OR ENGRAVED LETTERS AT LEAST 1" IN HEIGHT ON PLATE OR FITTING READING SERVICE DESIGN. FOR EXAMPLE, "SPRINKLER", "STANDPIPE" OR "SPRINKLER-STANDPIPE" (NFPA 13 16.12.5.8.1).
4. A SIGN SHALL ALSO INDICATE THE PRESSURE REQUIRED AT THE INLETS TO DELIVER THE GREATEST SYSTEM DEMAND (NFPA 13 16.12.5.8.2).
5. AT BALL DRIP VALVE-INSTALL 1/2 C.Y. 3/4" WASHED ROCK WRAPPED IN FILTER FABRIC.
6. SEE FIRE GENERAL NOTES FOR PLACEMENT AND FURTHER REQUIREMENTS.