

TYPICAL SECTION

NOTES

- 1. FINISHING, CURING, FORM WORK, PLACEMENT AND MATERIALS SHALL CONFORM TO WSDOT STANDARD SPECIFICATIONS.
- 2. SEE STD. ST-SID-1 FOR EXPANSION JOINTS AND SPACING.
- 3. EXPANSION JOINTS SHALL BE PLACED ADJACENT TO CATCH BASINS, INLETS AND AT POINTS OF TANGENCY ON STREETS, ALLEYS, AND DRIVEWAY RETURNS.
- 4. ALL JOINTS SHALL BE CLEAN AND EDGED.
- 5. FINISH SHALL BE LIGHT BROOM FINISH, PERPENDICULAR TO CURB FACE.
- 6. ALL CURB AND GUTTER SHALL BE PLACED ON A MIN. OF 2" OF CRUSHED SURFACING TOP COURSE COMPACTED AS SPECIFIED IN WSDOT STANDARD SPECIFICATIONS.
- 8. SEE STD. U-STO-8 FOR THICKENED CURB AT CATCH BASINS.
- 9. 1/2" MAX LIP IN DRIVEWAY CUTS, NO LIP (FLUSH) IN CURB RAMP CUTS.



CONCRETE VERTICAL CURB AND GUTTER

ST-CG-1-Concrete-Vertical-Curb-and-Gutter.dwg

DRAWING NUMBER	ST-CG-1
SCALE	NONE
REVISION DATE	12/20
DEPARTMENT	PW