



NOTES:

1. SIDEWALKS SHALL BE 4" THICK IN NON-TRAFFIC AREAS, 6" THICK IN TRAFFIC AREAS & BEHIND ROLLED CURB.
2. FINISHING, CURING, FORM WORK, PLACEMENT AND MATERIALS SHALL CONFORM TO THE CURRENT WSDOT SPECS.
3. FULL DEPTH EXPANSION JOINTS SHALL GENERALLY BE PLACED TO MATCH THOSE PLACED IN ADJACENT CURB & GUTTER, WITH MAXIMUM SPACING OF 20 FEET. CONTRACTION JOINTS SHALL BE PLACED EVERY 5 FEET. FINAL SPACING DETERMINATION SHALL BE DECIDED BY THE CITY IN THE FIELD.
4. SUBGRADE SHALL BE COMPACTED AS SPECIFIED IN WSDOT STANDARDS AND SPECIFICATIONS.
5. THE FINISHED SIDEWALK SHALL BE COVERED BY CURING COMPOUND, WATERPROOF PAPER OR PLASTIC SHEETING IN THE EVENT OF RAIN OR OTHER INCLEMENT WEATHER.
6. ALL JOINTS SHALL BE CLEANED AND EDGED WITH AN EDGER HAVING A 1/8" RADIUS.
7. SIDEWALKS ARE TYPICALLY 5' WIDE, EXCEPT 7' IN SOME COMMERCIAL AREAS, OR AS APPROVED BY THE PUBLIC WORKS DIRECTOR. SIDEWALKS ARE WIDER THAN 7' IN CERTAIN ZONES (E.G. CITY CENTER).