



- 1 W = MAXIMUM WIDTH OF TRENCH. FOR PIPES 15" OR LESS IN DIA W=40". FOR PIPES 18" OR GREATER W=1-1/2 x I.D. + 18".
- 2 ALTERNATE LAID-BACK TRENCH TO MEET O.S.H.A. REQUIREMENTS (NO SLOPES STEEPER THAN 1:1 EXCEPT FOR ROCK). TRENCH SLOPES, SAFETY AND SHORING SHALL BE THE CONTRACTOR'S RESPONSIBILITY. PROTECT THE PUBLIC AT ALL TIMES.
- 3 TRENCH BACKFILL SHALL MEET THE REQUIREMENTS OF WSDOT 9-03.14(1) GRAVEL BORROW. SEE STD. ST-TRE-6 FOR COMPACTION REQUIREMENTS.
- 4 FOUNDATION GRAVEL IF REQUIRED BY THE ENGINEER TO REPLACE UNSUITABLE MATERIAL. SHALL BE FOUNDATION MATERIAL CLASS A. WSDOT 9-03.17.
- 5 SEE CITY OF LYNNWOOD STD. ST-TRE-1 FOR PAVEMENT AND PAVEMENT SUBGRADE.
- 6 VERTICAL TRENCH WALLS WITH SHORING TO CONFORM TO O.S.H.A. REGULATIONS.
- 7 SUBGRADE OR GROUND SURFACE IN NON-PAVED AREAS.
- 8 IN NON PAVED AREAS PROVIDE MIN. 4" TOPSOIL FOR LAWN AREAS, MIN 8" IN PLANTING AREAS.
- 9 DEWATERING OF TRENCH DURING CONSTRUCTION MAY BE REQUIRED.
- 10 ALL EXCAVATED MATERIAL TO BE LOADED OUT.

