



SECTION: PIPE BEDDING

NOTES:

1. LIMITS OF TRENCH
W = MAXIMUM WIDTH OF TRENCH
FOR PIPES 15" OR LESS IN DIAMETER W= 40" MINIMUM.
FOR PIPES 18" OR GREATER IN DIAMETER W= 1 1/2 X I.D. + 18".
2. GRAVEL BACKFILL FOR PIPE ZONE BEDDING SHALL BE EQUAL TO WSDOT 9-03.12 (3).
3. TRENCH DAMS SHALL BE DESIGNED AND INSTALLED BY THE CONTRACTOR FOR IMPERMEABLE SOILS ON SLOPES.
4. ALL FOUNDATION MATERIAL, IF REQUIRED, SHALL BE FOUNDATION MATERIAL CLASS "A" PER WSDOT SPEC 9-03.17.
5. COMPACTION SHALL COMPLY WITH WSDOT SPEC 2-06. SEE LYNNWOOD STD. ST-TRE-6 FOR ADDITIONAL INFORMATION.