



**NOTES:**

1. ALL D.I. JOINTS SHALL BE RESTRAINED WITH MEGALUG TYPE DEVICES OR APPROVED EQUAL.
2. ALL D.I. PIPES SHALL BE COATED WITH PROTECTO 401 OR APPROVED EQUIVALENT.
3. CHANNELIZE THE MANHOLE TO DIRECT THE DISCHARGE FROM THE DROP IN THE DIRECTION OF THE MAIN FLOW CHANNEL. DROP OUTLET SHALL BE ALIGNED WITH THE EXISTING CHANNEL WITH NO SHELF.