



#### NOTES:

1. VALVE OPERATING NUT EXTENSIONS ARE REQUIRED WHEN THE VALVE NUT IS MORE THAN THREE (3) FEET BELOW FINISHED GRADE. EXTENSIONS SHALL BE A MINIMUM OF ONE (1) FOOT LONG. ONLY ONE EXTENSION WILL BE ALLOWED PER VALVE.
2. ALL VALVE OPERATING NUT EXTENSIONS SHALL BE MADE OF STEEL, SIZED AS NOTED, AND PAINTED WITH TWO (2) COATS OF METAL RUST RESISTANT PAINT.
3. VALVE BOXES SHALL BE CAST IRON, TWO PIECE UNITS WITH CAST IRON VALVE BOX LID WITH TABS ALIGNED IN THE DIRECTION OF WATER FLOW.
4. VALVE BOXES SHALL BE ADJUSTED FLUSH WITH FINISHED PAVING. VALVE BOX COLLARS ARE REQUIRED IF VALVE BOX IS OUT OF PAVING AREA. COLLARS SHALL BE FLUSH WITH FINISHED GRADE. SLOPE COLLARS AWAY FROM LID AT 2% TYP.